



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

Fenster • windows
 Rollläden • shutters
 Türen + Tore • doors
 Fassaden • curtain walling
 Baubeschläge • building hardware

TEST CERTIFICATE NO. 19/05-A001-C1

Version 1.en

Applicant Işıldak İnşaat Taah. Tic.A.Ş.
 Mutlukent Mah.1986 Sk. No:20
 Ümitköy-Ankara-Türkiye

Test date July 31, 2019

Product name **Albert Genau Vertiflex Twin**

Type Vertical-Sliding guillotine window, with one fixed and two sliding panels parts vertically controlled by electric drive Aluminum, double glazing. (5-12-5/ Tempered)

Dimension (W x H) max. 3600 mm x 2600 mm

Performance According to test report No. 19/05-A001-B1 from July 31, 2019:

Air permability according to EN 12207 Class **3**

Water Tightness according to EN 12208 Class **9A**

Impact Resistance according to EN 14019 Class **I3/E5**

Measurement of deflection According to EN 12211/12210
+600 Pa: 47,5 mm.
-600 Pa: 48,0 mm.

Repeated pressure According to EN 12211/12210
+300 Pa / -300 Pa

Safety test According to EN 12211/12210
+900 Pa / -900 Pa

Validity Period of validity of standarts

Y. Altug
 Technical Manager



July 31, 2019